REPORT NO. A03.063

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 90376
PERMIT NO.
BASIN 087

NOTICE OF INTENT NO. 49145

1. OWNER Bob White
MAILING ADDRESS 2937 Flintridge Ct. Reno, NV 89511
ADDRESS OF WELL 220 Vermillion
VC Highlands, NV 89511

2. WELL LOCATION SW 1/4 SW 1/4 SEC 6 T 17 R 21 E Storey COUNTY
PERMIT NO. PARCEL NO 03-442-09 SUBDIVISION NAME

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Yellow clay, stone		0	25	25
White rock, some yellow, red rock		25		
& red clay		25	35	10
Hard purple rock w/ white specs		35	40	5
Hard reddish brown rock, some		40		
white rock		40	85	45
White sandy clay		85	110	25
Multi color soft & hard rock		110	120	10
White, red, brown rock & sandy		120		
white clay		120	150	30
Heavy clay yellow, brown-yellow		150		
rock		150	278	128
Multi color harder rock		278	305	227
Multi color rock & blue-gray clay	X	305	504	199

RECEIVED
03 JUL 30 AM 11:56
STATE ENGINEERS OFFICE

Notes: * Plugged by well log # 114776
* Replaced by well log # 114775

Date Started 6/26/03 Date Completed 7/1/03

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
Air	20+		1 1/2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 504 Depth Cased 504

HOLE DIAMETER (BIT SIZE)
10 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 380 Feet
8 Inches 380 Feet 504 Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	504

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 404 Feet to 424 Feet
From 464 Feet to 484 Feet
From Feet to Feet

SURFACE SEAL [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD [ ] Pumped [X] Poured

SEAL TYPE
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
[ ] Bentonite

GRAVEL PACKED [X] Yes [ ] No
From 50 Feet to 504 Feet

9. WATER LEVEL
Static Water Level 350 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature cool F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Driling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO ON SITE 2189
Signed R Thrall
By driller performing actual drilling on site or contractor
Dated July 24 2003