COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90382
Permit No.
Basin 107

NOTICE OF INTENT NO. 46432

1. OWNER RON & DONNA TUCKER (BRAD JOHNSON)
MAILING ADDRESS 11 PLEASANT VIEW DR
WELLINGTON, NV 89444

ADDRESS AT WELL LOCATION #11 PLEASANT VIEW CR
WELLINGTON, NV 89444

2. LOCATION SE ¼ NW ¼ Sec 12 T 11 N R 23 E LYON County

PERMIT NO. (Issued by Water Resources) 9-071-07 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN HARDPAN		0	6	6
BROWN DG SANDS		6	15	9
BROWN CLAY		15	27	12
DG SANDS		27	75	48
BROWN CLAY	XX	75	120	45
SMALL BROWN SANDS				
GREY CLAY VERY	X	120	140	20
SANDY				

RECEIVED
03 JUL 10 AM 10:42
STATE ENGINEERS OFFICE

Date started 5/22, 20 03
Date completed 5/23, 20 03

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
17	15	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	140

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100' ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 140 feet

9. WATER LEVEL
Static water level 40' feet below land surface
Artesian flow G.P.M 17 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING & PUMP INC. (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed [signature] By driller performing actual drilling on site or contractor
Date 6/15/03