WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90383
Permit No.
Basin 087

NOTICE OF INTENT NO. -51516

1. OWNER Truckee Meadows Water Authority VSMW-S
MAILING ADDRESS 1155 Corporate Boulevard
Reno, NV 89510

ADDRESS AT WELL LOCATION 2545 D Street, Sparks, NV.

2. LOCATION SW 1/4 SE 1/4 Sec. 6 T 19N N/S R 20 E Washoe County
PERMIT NO. R-16 (Issued by Water Resources) | 031-302-36 (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	15	15
Sand		15	25	10
Boulders, gravel,sand		25	65	40
Gravel and sand		65	80	15
Gravel, sand, and clay		80	125	45
Gray clay		125	138	13
Brown clay		138	150	12
Sand, gravel, and clay		150	170	20
Gravel		170	190	20

Date started 8/23/2003, 19__
Date completed 8/25/2003, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12	Not. Meas.	1

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 186 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	20	Feet
6.5	Inches	20	Feet	190	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7.625	17.02	0.250	+2	20
2.5		Sch. 80	+1.7	186

Perforations:
Type perforation Slot
Size perforation 0.050"
From 146 feet to 186 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 139 feet to 190 feet

9. WATER LEVEL
Static water level 87.5 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995
Signed Guadalupe Jacobo (By driller performing actual drilling on-site or contractor)
Date 9/4/03

USE ADDITIONAL SHEETS IF NECESSARY

RST-L