REPORT NO. A03.064

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 90393
PERMIT NO.
BASIN 083
NOTICE OF INTENT NO. 48860

OWNER: Jerry Smith
WELL OWNER ADDRESS: 2424 Cartwright Rd. VC Highlands, Nv. 89521
ADDRESS OF WELL: 2424 Cartwright Rd. VC Highlands, Nv. 89521
WELL LOCATION: NE 1/4 NW 1/4 SEC. 32 T. 18 R. 21 E. Storey COUNTY
PERMIT NO. PARCEL NO. 03-012-10 SUBDIVISION NAME

3. TYPE OF WORK: New Well / Replace / X Recondition / Deepen / Plug / Other
4. PROPOSED USE: X Domestic / Irrigation / Test / Municipal/Industrial / Monitor / Stock
5. WELL TYPE: Cable / Rotary / PVC / Air / Mud

7. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS

8. WELL CONSTRUCTION

Depth Drilled Depth Cased

HOLE DIAMETER (or) SIZE

Inches Feet Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D.	Weight/Ft	Wall Thickness	From	To

PERFORATIONS

Type Perforation: Millsknife Size Perforation
From 74 Feet to 105 Feet
From 127 Feet to 149 Feet
From 200 Feet to 234 Feet

SURFACE SEAL: Yes / No Seal Type: Neat Cement / Cement Grout / Concrete Grout / Bentonite
Seal Depth
PLACEMENT METHOD: Pumped / Poured
GRAVEL PACKED: Yes / No
From Feet to Feet

9. WATER LEVEL
Static Water Level 140 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature F Quality

RECEIVED
JUL 30 AM 11:26
STATE ENGINEERS OFFICE

Notes: Also perforated from 260' to 294'. Perforated every 18" with Mills knife.

Date Started Date Completed

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502
NV CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. 2189
Signed
Date July 8, 2003

WELL TEST DATA

TEST METHOD: Bailer / X Pump / Air Develop

	GPM	DRAWDOWN	TIME FIRST
Pump	14.6		1 hour