

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 90398
 Log No. _____
 Permit No. _____
 Basin 153
 NOTICE OF INTENT NO. 49684

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY

1. OWNER SCOTT SNELLING CONSTRUCTION ADDRESS AT WELL LOCATION 210 POTOSI
 MAILING ADDRESS 318 SYDNEY LN DAYTON, NV 89403

2. LOCATION SE 1/4 SE 1/4 Sec 9 T 16 N R 22 E LYON County
 PERMIT NO. 16-292-17

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BLOW SANDS		0	3	3
HARDPAN SANDS		3	6	3
SANDY BLOW SANDS		6	21	15
COURSE DG SANDS		21	87	66
BROWN CLAY		87	146	59
GRAY CLAY		146	167	21
FRACTURED DG SAND	XXX	167	200	33

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	200

Perforations:
 Type perforation FACTORY MILL SLOT
 Size perforation 3 X 3/32
 From 180 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. 25+ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name CAPITAL CITY WELL DRILLING & PUMPS INC.
 (CONTRACTOR)

Address 20 KIT KAT DRIVE
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 55548
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
 Signed Rick Crane
 By driller performing actual drilling on site or contractor
 Date 6/28/03

Date started 6/24, 20 03
 Date completed 6/25, 20 03

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.			
<u>25+</u>			
Draw Down (Feet Below Static)			
<u>25</u>			
Time (Hours)			
<u>3 HRS</u>			

RECEIVED
 03 JUL 10 AM 10:42
 STATE ENGINEERS OFFICE