WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90463
Permit No.
Basin 207

NOTICE OF INTENT NO. 43197

1. OWNER Robert Brown
MAILING ADDRESS HCR 38 Box 75
Mt. Char Leston Las Vegas NV 89624

ADDRESS AT WELL LOCATION E, ½ Lot 10 Block 9
Lund ten acre plat

2. LOCATION NW ¼ SW ¼ Sec. 17 T. 12 N/S R. 62 E. white pine County
PERMIT NO. N/A (Issued by Water Resources) 13-042-09 (Parcel No.) none (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	1.5	
cemented gravel		1.5	2	
Sand gravel		2	24	
Sandy clay		24	28	
gravel conglomerate		28	37	
clay		37	41	
gravel con.		41	47	
clay		47	55	
Sandy gravel con		55	80	
gravel	water	80	84	
cobbles		84	88	
Sandy clay		88	95	
gravel	water	95	97	
clay		97	99	
gravel	water	99	101	
clay		101	109	
gravel	water	109	111	
Sandy clay		111	120	
gravel	water	120	124	

RECEIVED
03 SEP 15 AM 11:55
STATE ENGINEERS OFFICE

Date started July 5, 2003
Date completed August 18, 2003

7. WELL TEST DATA

TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	1	1

8. WELL CONSTRUCTION
Depth Drilled 124 Feet Depth Cased 124 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
8 Inches	50 Feet	87 Feet
6 Inches	87 Feet	124 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	129	.188	-1	124

Perforations:
Type perforation mill
Size perforation 5 x 2.25 x 6 Row
From feet to feet
From 84 feet to 124 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 80 feet

9. WATER LEVEL
Static water level 82 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Maynard Well Drilling (Contractor)
Address Po Box 64 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 47226
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed [signature] (By driller performing actual drilling on site or contractor)
Date Sept 11-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627