



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48428

1. OWNER PEGGY RITTER ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 10995 Silver Knolls Blvd. Same
Reno, Nevada 89506
 2. LOCATION SW 1/4 SW 1/4 Sec. 24 T. 21N N/S R 18 E Washoe County
 PERMIT NO. 086-203-26 Silver Knolls
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING				
Static water level @150 feet				
Clean out rust 165 to 169				
Yield Maybe 1 to 2 GPM				
Gray clay		169	171	2
Brown sandy clays		171	188	17
Soft zone	X	188	191	3
Brown sandy clay		191	205	14
Soft zonw	X	205	212	7
Brown sandy clay		212	224	12
Soft zone	X	224	229	5
Brown sandy clay		229	240	11
Soft zone	X	240	242	2
Brown sandy clay		242	249	7
Soft zone	X	249	254	5
Brown sandy clays		254	261	7
Soft zone	X	261	269	8
Brown sands clays		269	283	14
Soft zone	X	283	285	2
Brown sandy clays		285	310	25
Soft zone	X	310	316	6
Brown sandy clays		310	325	15

8. WELL CONSTRUCTION
 Depth Drilled 325 Feet Depth Cased 325 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 169 Feet 325 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	325

Perforations: factory sawed slot
 Type perforation _____
 Size perforation 3/32 x 3 x 5 around
 From 212 feet to 238 feet
 From 240 feet to 290 feet
 From 310 feet to 320 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Depth of Seal deepening Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 169 feet to 325 feet

9. WATER LEVEL
 Static water level 174 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 0022549
 issued by the State Contractor's Board.
 Nevada driller's license number 923 issued by the
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date July 30, 2003

Date started 7-28-03, 19____
 Date completed 7-29-03, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30+</u>		

RECEIVED
 03 AUG 11 PM 12:40
 STATE ENGINEERS OFFICE