



Log No. 90759
 Permit No. _____
 Basin 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48993

1. OWNER Kim Robinson ADDRESS AT WELL LOCATION 3150 E. Cougar Silver Springs
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 SW 1/4 Sec 21 T 17 N/S R 25 E Hyon County
 PERMIT NO. 17-484-07 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other med

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>6</u>	
<u>Tan Clay</u>		<u>6</u>	<u>36</u>	
<u>Sand Gravel</u>		<u>36</u>	<u>91</u>	
<u>Brown Clay</u>		<u>91</u>	<u>138</u>	
<u>Sand Gravel</u>		<u>138</u>	<u>172</u>	
<u>Tan Clay</u>		<u>172</u>	<u>186</u>	
<u>Gravel Sand</u>		<u>186</u>	<u>220</u>	

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>3/16</u>	<u>71</u>	<u>20</u>
<u>6 5/8</u>	<u>9.00</u>	<u>Sch 20 Pvc</u>	<u>20</u>	<u>220</u>

Perforations:
 Type perforation Seal/Saw
 Size perforation 1 1/4 x 6 Long Stems
 From 200 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 220 feet

9. WATER LEVEL
 Static water level 43 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Teach Drilling Inc Contractor
 Address Po Box 579 Contractor
Silver Springs NV 89429
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1827
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 5-20-03

Date started 5-18
 Date completed 5-19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	<u>Produced about 50</u>	<u>6 Pm</u>	

03 JUL - 3 / 10:49
 STATE ENGINEERS OFFICE