

OFFICE USE ONLY  
 Log No. 90813  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19009

1. OWNER Rick Bertucci ADDRESS AT WELL LOCATION 134 Hwy 395 Gardnerville, NV  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE 1/4 NW 1/4 Sec 05 T 11 N/S R 21 E Douglas County  
 PERMIT NO. 1121-05-000-008 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVG  
 Air  Other MUC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Gravelly Sand</u>		<u>0</u>	<u>16</u>	<u>✓</u>
<u>Coarse Sand</u>		<u>16</u>	<u>183</u>	
<u>Gravelly Sand Fractured</u>		<u>163</u>	<u>240</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 11 1/2 Feet  
12 1/8 Inches 100 Feet 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>3/16</u>	<u>±1</u>	<u>240</u>

Perforations:  
 Type perforation M/S slot  
 Size perforation \_\_\_\_\_  
 From 180 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 180 feet to 240 feet

9. WATER LEVEL  
 Static water level 135 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 7-15, 2003  
 Date completed 7-16, 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>Induced about 40</u>	<u>6PM</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Teach Drilling Inc  
 Address PO Box 599 Silver Springs NV 89409  
 Nevada contractor's license number issued by the State Contractor's Board 00318411  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 10277  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 7-17-03

RECEIVED  
 23 AUG 25 AM 9:31  
 STATE ENGINEERS OFFICE