

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 90823
 Permit No. 18975
 Basin 153
 NOTICE OF INTENT NO. 48687

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Jerry Sestavovich ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS HC 62 Box 62640 Diamond Valley
Eureka, NV 89316 Eureka, NV
 2. LOCATION SW 1/4 NE 1/4 Sec. 11 T 20 N5 R 53 E Eureka County
 PERMIT NO. 18975 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel & Cobble				
Stone		0	55	55
Clay		55	57	2
Sand		57	60	3
Gravel		60	73	13
Clay		73	76	3
Gravel w/Clay		76	83	7
Gravel w/Clay Stringers		83	93	10
Clay w/Gravel		93	98	5
Gravel		98	137	39
Gravel w/Clay Stringers		137	145	8
Gravel		145	163	18
Clay & Gravel		163	173	10
Gravel	X	173	190	17
Clay W/Gravel Stringers		190	195	5
Gravel	X	195	230	35
Gravel w/Clay Stringers		230	307	77
Clay		307	325	18

Date started 6/13/03 _____ 19____
 Date completed 6/20/03 _____ 19____

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input checked="" type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
1030	38	1	
1160	35	1	

8. WELL CONSTRUCTION
 Depth Drilled 325 Feet Depth Cased 325 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
36 Inches 0 Feet 50 Feet
26 Inches 50 Feet 325 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30	20.75	.065	0	50
16	42.00	.250	0	185
16		1 1/4"	185	325

Perforations:
 Type perforation Saw Cut
 Size perforation .100
 From 185 feet to 325 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 0 feet to 325 feet

9. WATER LEVEL
 Static water level 172 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc Contractor
 Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
 Signed William Parsons
 By driller performing actual drilling on-site or contractor
 Date 7/14/03

RECEIVED
 03 JUL 15 AM 11:03
 STATE ENGINEERS OFFICE