

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48431

1. OWNER RICHARD & ANN MCNEELY ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1200 Goldstone Road Same
Reno, Nevada 89506
 2. LOCATION NE 1/4 SE 1/4 Sec. 30 T. 22N N/S R. 19 E Washoe County
 PERMIT NO. 079-352-05 Red Rock Estate
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL ABANON/PLUG				
9-23-03				
Static water level @126 feet				
Total depth @520 ft				
Perforate from 480 - 380				
360 - 260				
240 - 200				
180 - 75				
9-24-03				
Run tremie pipe to 504 feet				
Mix & pump 60 sack of cement. Fluid level @116				
Pull tremie pipe to 169 feet				
Let set				
Run tremie pipe to 231 feet.				
Mix & pump 39 sacks of cement to bring over top				
9-25-03				
Check cement level @9 feet/Water level @6 feet				
Top off cement with 1 sack of cement. Cut off casing below grade, finish at grade.				
Equipment used:				
Ingersoll-Rand T4W Drill, LT9000 Rig Tender, F450 Support Truck, Holt down hole air operated perforator, Grout mixer & pump, 2 man crew				
Continued below:				

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By drill performing actual drilling on site or contractor
 Date September 28, 2003

Date started September 23, 2003, 19____
 Date completed September 25, 2003, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
Continued:			
Materials used:			
100 sacks of Portland Cement Type II			
Location:			
1000ft. North of South boundary			
550 ft West of East boundary			