

OFFICE USE ONLY
 Log No. 90849
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49137
 ADDRESS AT WELL LOCATION 240 HANSEN LN GARDNERVILLE, NV 89410

1. OWNER Douglas L. Champlin
 MAILING ADDRESS POBx 5974 Incline Village NV 89450
 2. LOCATION SE 1/4 SW 1/4 Sec 34 T 13 N R 19 E Douglas County
 PERMIT NO. 131934002026
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		1	3	3
black fine SAND	X	3	8	5
	05'			
Black grey SAND fine to med	X	8	25	17
Fine med coarse Decomposed granite	X	25	180	155

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>12</u>	<u>140</u>

Perforations:
 Type perforation Factory slot
 Size perforation 3/32 x 13"
 From _____ feet to _____ feet
 From 140' feet to _____ feet
 From _____ feet to 180' feet
 From pipe from feet to 180' 180' 15 1 1/2" x 3" slot feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 180 feet

9. WATER LEVEL
 Static water level + ground level feet below land surface
 Artesian flow yes 1.5 +/- G.P.M. P.S.I.
 Water temperature 48 °F Quality _____

Date started 9.14.03, 19____
 Date completed 9.19.03, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>100+</u>		<u>2 1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sierra Nevada Drilling + Pump LLC Contractor
 Address 3540 GREEN ACRES DR Carson City NV. 89705 Contractor
 Nevada contractor's license number 52078 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1902 Division of Water Resources, the on-site driller
 Signed John B. Reich
 by driller performing actual drilling on site or contractor
 Date 9.15.03

RECEIVED
 13 OCT - 1 AM 11:28
 STATE ENGINEERS OFFICE