

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

office use only
 Log No. **90963**
 Permit No.
 Basin. **089**

NOTICE OF INTENT NO 49120
3825 Doc Olena Ct

1. OWNER **Ben Haynie**
 MAILING ADDRESS **1358 Porter Dr**
Minden NV

ADDRESS AT WELL LOCATION

2. Location **NW 1/4 SW 1/4 Sec 5 T 16N R 20E** Washoe County
 PERMIT NO. **PARCEL NO. 050-301-46** SUBDIVISION NAME

3. WORK PERFORMED | 4. PROPOSED USE | 5. WELL TYPE
 New Well Replace Recondition | Domestic Irrigation Test | Cable Rotary RVC
 Deepen Abandon Other | Municipal/Industrial Monitor Stock | Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & clay.		0	95	95
Gravels.		95	132	37
Granite.		132	140	0

8. WELL CONSTRUCTION
 Depth Drilled **140 feet** Depth Cased **140 feet**
 HOLE DIAMETER (BIT SIZE)

	From	To
12 3/4 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	140

Perforations:
 Type Perforation **Factory**
 Size perforation **3/32 x 3"**

From	To
108 feet	128 feet
feet	feet
feet	feet
feet	feet
feet	feet


Surface Seal YES No Seal Type:
 Depth of Seal **60 feet** Neat Cement
 Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **60 feet** to **140 feet**

9. WATER LEVEL
 Static water level **60 feet** below land surface
 Artesian flow **0 GPM 0 P.S.I.**
 Water Temperature **cold** Degrees F Quality

Date started **7-24 -03**
 Date completed **7*28 -03**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)		
80	20			
100	40			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
 NV Contractors No. **14170**
 NV Driller's Lic (on site) **2121**
 Signed 
 By driller performing actual drilling on site or contractor
 Date **8-8 -03**

RECEIVED
 03 AUG 25 PM 1:03
 STATE ENGINEERS OFFICE