WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

MW-1

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91327
Permit No.
Basin 212

NOTICE OF INTENT NO. 22041

1. OWNER Southern Nevada Paving
MAILING ADDRESS 3555 Polaris Avenue, Las Vegas NV 89103
ADDRESS AT WELL LOCATION 413 East Gowan Road, Las Vegas NV 89030

2. LOCATION NE 1/4 SW 1/4 Sec 10 T 20S N/S R 61 E Clark County
PERMIT NO (Issued by Water Resources) — Parcel No. 139-10-702-001 — Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	0.25'	0.25'
GRAVEL and SAND		0.25'	8'	7.75'
Caliche		8'	11.5'	3.5'
CLAY and Caliche		11.5'	18'	6.5'
CLAY		18'	33'	15'
SILTY CLAY; tr. coarse sand		33'	57'	24'
CLAY; some Caliche		57'	59'	2'
CLAY		59'	68'	9'
Fine SAND		68'	70'	2'
SILTY CLAY		70'	75'	5'
CLAY; tr. silt or fine sand		75'	84'	9'
CLAY		84'	90'	6'
CLAY; tr. fine sand		90'	116'	26'
Caliche (part. cemented f.g. silt/clay soil		116'	124'	8'

Date started September 17, 2003
Date completed September 17, 2003

7. WELL TEST DATA
TEST METHOD ☐ Bailer ☐ Pumped ☐ Air Lift

G.P.M	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 124 Feet Depth Cased 124 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	124 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		0.308	0	124

Perforations:
Type perforation Factory Slot PVC
Size perforation 0.020 inch
From 84 feet to 124 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1.5 feet
Placement Method ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 82 feet to 124 feet

9. WATER LEVEL
Static water level 94 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATE
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Converse Consultants (Contractor)
Address 731 Pilot Road, Suite H, Las Vegas NV 89119 (Contractor)
Nevada contractor's license number
Issued by the State Contractor's Board 48947
Nevada driller's license number issued by the
Division of Water Resources, the on-site driller M 1589
Signed (By driller performing actual drilling on-site or contractor)
Date October 22, 2003

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (0)-627