

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 91528
 Permit No. _____
 Basin 164

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52434

1. OWNER **AMES CONSTRUCTION** ADDRESS AT WELL LOCATION **Hot Springs Road Pumping Well #2**
 MAILING ADDRESS **3737 WEST 2100 SOUTH WEST VALLEY CITY, UT 84120**

2. LOCATION SE 1/4 SE 1/4 Sec. 5 T 15N N/S R 20E E **CARSON** County
 PERMIT NO. C-226 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	
Sand	x	2	31	29
Clay w/Sand & Samll gravel	x	31		
Sand w/small gravel	x	43	52	9
Sand & gravel w/clay		52	58	6
Sand & gravel		58	62	4
Sand Broken Rock		62	65	3
Bed Rock w/layers of green rock			125	60
ABANDONMENT				
Abandon this well pump 6 sack sand grout from 125ft to surface.		0	125	125

8. WELL CONSTRUCTION

Depth Drilled 125 Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>14-3/4</u> Inches	<u>0</u> Feet <u>125</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation N/A
 Size perforation N/A

From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 125ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From N/A feet to N/A feet

Date started 11/16/03
 Date completed 11/19/03

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL

Static water level 8 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Humboldt Drilling & Pump Co., Inc.** Contractor
 Address **4675 W. Winnemucca Blvd** Contractor
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 56797
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1572

Signed Tom A. Tomp
 By driller performing actual drilling on-site or contractor
 Date 12/17/20

RECEIVED
 03 DEC 22 PM 11:17
 STATE ENGINEERING OFFICE