WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91721
Permit No.
Basin 103

NOTICE OF INTENT NO. 46643

1. OWNER Jim & Jennifer Renth
MAILING ADDRESS 270 Imperial Road
Dayton, NV 89403

ADDRESS AT WELL LOCATION 270 Imperial Road Dayton
Nevada 89403

2. LOCATION NW 1/4 NE 1/4 Sec. 9 T 16N N/S R 22E E Lyon County
PERMIT NO. Issued by Water Resources
19-141-08 Parcel No.
Subdivision Name

3. **WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. **PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Run In Perforator and check for 50 foot sanitary seal Per Tom Gallager,found seal,remove perforator cut off casing below finised grade,install trimie to 106 feet and pump approx 3662 lbs of neat cement from total depth to surface to abandon well.				

RECEIVED 2003 JUL 18 AM 10:57 STATE ENGINEER'S OFFICE

Date started 06/13/2003 , 19__
Date completed 06/13/2003 , 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.5	98	30 min

8. **WELL CONSTRUCTION**
Depth Drilled 106 Feet Depth Cased 106 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	9.3	.134	-1	106

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal In Place
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. **WATER LEVEL**
Static water level 96 feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service (Contractor)
Address P.O. Box 60130 (Contractor)
Reno,Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 35387-B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
Signed Larry Welch (By driller performing actual drilling on-site or contractor)
Date 06/16/2003

USE ADDITIONAL SHEETS IF NECESSARY