

KL-#3

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY

Log No. 91854
Permit No.
Basin 87

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 410094

1. OWNER Public Works/City of Reno
MAILING ADDRESS P.O. Box 1900 Reno, NV. 89505
ADDRESS AT WELL LOCATION West of West St. in Center of 3rd St. Reno, NV. 89505
2. LOCATION SW 1/4 NE 1/4 Sec. 11 T. 19 N. R. 19 E Washoe County
PERMIT NO. DEN-30 Parcel No. 011-370-23 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Sanis

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0'	5'	5'
Fill - Bluish Gray - Dry		5'	9'	8.5'
Clayey Dirt - Reddish Brown - Dry		9'	12'	3'
Granite Boulder		12'	110'	4'
Gravel - Greenish Brown - Dry		110'	24'	8'
Cobbles - Gray - Dry		24'	25'	1'
Clay - Brown - Dry		25'	26'	1'
Clayey Dirt - Brown - Moist		26'	35'	9'

8. WELL CONSTRUCTION
Depth Drilled 35' Feet Depth Cased 35' Feet
HOLE DIAMETER (BIT SIZE)
From 6" Inches To 0' Feet 35' Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Sch. 40	P.U.C.	0'	25'

Perforations:
Type perforation Factory Cut
Size perforation 0.020"
From 25' feet to 35' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 23' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No 3' Concrete
From 35' feet to 23' feet

9. WATER LEVEL
Static water level None at Time of Install feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

Date started 1-13-2004
Date completed 1-13-2004

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Phillip Cramer / Boast Longyear Contractor
Address P.O. Box 1000 Dayton, NV. 89403
32 Stokes Dr. Dayton, NV. 89403
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2148
Signed Phillip E. Cramer
By driller performing actual drilling on site or contractor
Date 1-15-04