


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



office use only
Log No. 92028
Permit No.
Basin 069

NOTICE OF INTENT NO 51548

1. OWNER **Chris Vournazos**
MAILING ADDRESS **4755 Eastlake Blvd**
Reno NV

ADDRESS AT WELL LOCATION **4755 Eastlake Blvd**

2. Location **SE 1/4 SE 1/4 Sec 5 T 16N R 20E** **Washoe County**
PERMIT NO. **PARCEL NO. 050-302-30** SUBDIVISION NAME **New Washoe City**

3. WORK PERFORMED | 4. PROPOSED USE | 5. WELL TYPE
 New Well | Replace | Recondition | Domestic | Irrigation | Test | Cable | Rotary | RVC
 Deepen | Abandon | Other | Municipal/Industrial | Monitor | Stock | Air | Other | Mud

6. LITHOLOGIC LOG					8. WELL CONSTRUCTION					
Material	Water Strata	From	To	Thickness	Depth Drilled	HOLE DIAMETER (BIT SIZE)	Depth Cased	From	To	
Sand.		0	55	0	10 5/8 inches		0 feet	50 feet	140 feet	
Clay.		55	107	-55	8 3/4 inches		50 feet	140 feet	188 feet	
Granite.		107	188	81	6 1/8 inches		130 feet	188 feet		
					CASING SCHEDULE					
					Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)	
					0	6 5/8	12.94	188	+1 1/2	140
					0	5	6.96	188	130	188
					Perforations:					
					0	Type Perforation	Factory			
					0	Size perforation	3/32 x 3"			
					0	From	120 feet to 140 feet			
					0	From	148 feet to 188 feet			
					0	From	feet to feet			
					0	From	feet to feet			
					0	From	feet to feet			
					0	From	feet to feet			
					0	Surface Seal	<input checked="" type="checkbox"/> YES No	Seal Type:		
					0	Depth of Seal	50 feet	Neat Cement		
					0		<input checked="" type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Cement Grout		
					0		Poured	Concrete Grout		
					0	Gravel Packed:	<input checked="" type="checkbox"/> Yes No			
					0	From	50 feet to 140 feet			
					9. WATER LEVEL					
					0	Static water level	60 feet below land surface			
					0	Artesian flow	0 GPM 0 P.S.I.			
					0	Water Temperature	cold Degrees F	Quality		

RECEIVED
 09/16/03 11:55
 COUNTY ENGINEERS OFFICE

Date started **9-8 -03**
Date completed **9-12 -03**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)	
12	80		
15	100		
20	120		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
 NV Contractors No. **14170**
 NV Driller's Lic (on site) **2121**
 Signed Steve McKay
 By driller performing actual drilling on site or contractor
 Date **9-16 -03**