

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49655

1. OWNER Allen & Rebecca Stand ADDRESS AT WELL LOCATION 4405 W. QUINCE  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 SE 1/4 Sec. 33 T 18 N/S R. 24 E Lyon County  
 PERMIT NO. 18-491-02 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<del>DIRT-ROCK</del>		0	18	18
<del>LARGE GRAVEL</del>		18	80	62
<del>WET CLAY-GRAVEL</del>		80	96	16
<del>CLAY-GRAVEL</del>		96	130	34
<del>LAVA ROCK</del>		130	246	116
<del>BROWN CLAY-GRAVEL</del>		246	290	44
<del>BLACK FRACTURED ROCK</del>		290	310	20

8. WELL CONSTRUCTION  
 Depth Drilled 310 Feet Depth Cased 310 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 50 Feet  
9 1/8 Inches 50 Feet 310 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>+1</u>	<u>309</u>

Perforations:  
 Type perforation Factory milled  
 Size perforation 2 3/32" x 3"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 290 feet to 310 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 53 ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 53 feet to 310 feet

9. WATER LEVEL  
 Static water level 126 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality CLEAR

Date started 18 Sep 2003  
 Date completed 25 Sep 2003

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>8-10</u>		<u>1.0</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name \_\_\_\_\_  
 Address Blain Drilling & Pump Co.  
P.O. Box 1255  
Carson City, NV 89702  
 Nevada contractor's license number issued by the State Contractor's Board 46498  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167  
 Signed Jack Dotson  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_