WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92158
Permit No.
Basin 66

NOTICE OF INTENT NO. 51834

1. OWNER Newmont Gold Corp
MAILING ADDRESS P.O Box 388
Valmy NV, 89438

ADDRESS AT WELL LOCATION Twin Creeks mine

2. LOCATION NE ¼ SE ¼ Sec. 30 T 39 N/S R 43 E Humbolt County
PERMIT NO. SE
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
m/o 30-20A				
Place 6½ Cubic				
yards of ~~[illegible]~~ ¼"				
gravel in hole				
with trimmy from Bottom				
Place Kwik Plug Seal				
on top of gravel				
5 Sacks Kwik plug				
Fine - with trimmy				
place 800 gallons				
Abandonite in hole				
with trimmy				
pour 50' Cement				
Seal and Build				
monument.				
Develope well				
with Air and Trimmy				
well Clean up good				
through 4½ Casing only				

RECEIVED
FEB - 9 AM
ENGINEERS

Date started 01/07/04 2004, 19
Date completed 01/12/04 2004, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	120 -	150	

8. WELL CONSTRUCTION
Depth Drilled 700 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14¾ Inches	0 Feet	40 Feet
10 Inches	40 Feet	700 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4½	PVC	SC 80	+3	700
1½	PVC	SC 80	+3	700

Perforations:
Type perforation ~~[illegible]~~ Slot PVC
Size perforation .020
From 4½" 340 feet to 680 feet
From 1½ 480 feet to 680 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 300 feet to 700 feet

9. WATER LEVEL
Static water level 190 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling
Contractor
Address P.O. Box 2748
Contractor
Elko NV, 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller m-2089
Signed [signature]
By driller performing actual drilling on site or contractor
Date 01/12/04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627