

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 92181
 Permit No. _____
 Basin 212
 NOTICE OF INTENT NO. 25828

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY

1. OWNER BEAZER HOMES HOLDING CORP ADDRESS AT WELL LOCATION Tropicana & Broadbent
 MAILING ADDRESS 4670 S FORT APACHE RD #200 LAS VEGAS, NV
LAS VEGAS, NV 89147

2. LOCATION NW 1/4 NE 1/4 Sec 27 T 21 S R 61 E CLARK County
 PERMIT NO. DW-1172 Parcel No. 161-27-510-005 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen
 Abandon Other Dewater
 4. PROPOSED USE Dewater
 Domestic Irrigation Test Monitor Stock
 Municipal/Industrial Other

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
4-dewater wells				
Depth 40'				
Sandy clay		0	8'	
Silt	XX	8'	21'	
Silt/Gray clay	X	21'	40'	
DCNR/DWR RECEIVED FEB 17 2004 LAS VEGAS OFFICE				

8. WELL CONSTRUCTION

Depth Drilled 40' Feet Depth Cased 40' Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
24 Inches _____ 0 Feet _____ 40 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	<u>36.71</u>	<u>.0250</u>	<u>0</u>	<u>40</u>

Perforations:
 Type perforation Machine
 Size perforation 1/4 x 2.5 x 3 rows @ 13
 From 0 feet to 40 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Depth of Seal _____
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level _____ 18' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ALLEN DRILLING INC. (CONTRACTOR)
 Address 4015 WEST TOMPKINS AVE. (CONTRACTOR)
LAS VEGAS, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 2/9/04

Date started 1/28, 20 04
 Date completed 1/28, 20 04

7. WELL TEST DATE

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.		