


REPORT NO. **A04.006**

STATE OF NEVADA
DIVISION OF WATER RESOURCES



LOG NO. 92209
PERMIT NO. _____
BASIN 87

WELL DRILLER'S REPORT

NOTICE OF INTENT NO. **51464**

1. OWNER Michael Drinkwater ADDRESS OF WELL 1945 Palmira Dr.
MAILING ADDRESS 996 Wheatland Ct. Reno, NV 89511 Reno, NV 89511
2. WELL LOCATION **SW** 1/4 **SW** 1/4 SEC. **7** T **18** R **20** E **Washoe** COUNTY
PERMIT NO _____ PARCEL NO **44-281-02** SUBDIVISION NAME _____

3. TYPE OF WORK

New Well Replace Recondition
 Deepen Plug Other

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Dirt Brown Clay Cobbles		0	16	16
Greenish Brown Silty Clay		16		
& Coarse Sands		16	23	7
Small Rock Sand Volcanic Rock		23	65	42
Coarse Sand Volcanic Rock		65		
& Reddish Brown Clay		65	70	5
Army Green Sand, Clay		70		
& Coarse Sand		70	140	70
Specs of Army Grn. Silty Clay,		140		
Coarse Sand, In & Out Soft Spots		140	238	138

8. WELL CONSTRUCTION

Depth Drilled **238** Depth Cased **238**

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches **0** Feet **238** Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	238

PERFORATIONS:

Type Perforation **Factory** Size Perforation **3/32 X 3**
From **178** Feet to **218** Feet
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet

SURFACE SEAL: Yes No SEAL TYPE:
Seal Depth **100'** Neat Cement
 Cement Grout
PLACEMENT METHOD: Pumped Concrete Grout
 Poured Bentonite

GRAVEL PACKED: Yes No
From **100** Feet to **238** Feet

9. WATER LEVEL

Static Water Level **30? +/-** Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature **Cool** F Quality **Clear**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Aqua Drilling & Well Service, Inc.**
Address **675 Edison Way**
Reno, NV 89502

DRILLER'S LIC. NO. _____
NV. CONTRACTOR'S LIC. NO. **15291** ON SITE **2189**

Signed Roger Withall
By driller performing actual drilling on site or contractor

Dated **January 22, 2004**

7. WELL TEST DATA

TEST METHOD Bailer Pump Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		1hr. 10 min.

Notes :