


REPORT NO. **A04.009**

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT



LOG NO. 92247
PERMIT NO. _____
BASIN 87

NOTICE OF INTENT NO. **51490**

1. OWNER **Evan Marchant**
MAILING ADDRESS **3156 Waterfield Dr. Sparks, NV 89434**
2. WELL LOCATION **NW 1/4 NW 1/4 SEC. 1 T 19 R 20 E Washoe** COUNTY
PERMIT NO. _____ PARCEL NO. **030-204-06** SUBDIVISION NAME _____

ADDRESS OF WELL **5029 Pleasant View Dr. Sparks, NV 89434**

3. TYPE OF WORK

New Well Replace Recondition
 Deepen Plug Other

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Rock Brown Dirt		0	5	5
Reddish Brown Clay & Vol. Rock		5	18	13
Red Volcanic Rock & Red Clay		18	40	22
Mostly Red Volcanic Rock		40	70	30
Dark Gray Volcanic Rock		70		
& Traces Of Clay		70	85	15
Hard Rock & Dark Blue Rock		85	95	10
Sandy Brown, Yellow, Red Clay Mix		95	110	15
Yellow Rock Mix & Sandy Clay		110	165	55
Multi Color V.R. Yellow Sandy Clay		165	190	25
Clay Multi Color Volcanic Rock		190	230	40
Hard Rock & Multi Color Rock		230	260	30
Hard Red, & Dark Blue Vol. Rock		260		
& Mixed Clay		260	290	30
Dark Green Hard Rock		290	390	100
Dark Green, Blue Rock		390		
With Specs of Yellow Clay		390	460	70
Gray Blue Clay & Multi Color Rock		460	490	30
Blue Gray Clay & Clay Stone Rock		490	558	68

8. WELL CONSTRUCTION

Depth Drilled **558** Depth Cased **558**
HOLE DIAMETER (BIT SIZE)
10 Inches **0** Feet **50** Feet
8 1/2 Inches **50** Feet **558** Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	558

PERFORATIONS:

Type Perforation **Factory** Size Perforation **3/32 X 3**
From **498** Feet to **538** Feet
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet

SURFACE SEAL:

Yes No SEAL TYPE:
 Neat Cement
 Cement Grout

PLACEMENT METHOD:

Pumped Concrete Grout
 Poured Bentonite

GRAVEL PACKED:

Yes No
From **50** Feet to **558** Feet

9. WATER LEVEL

Static Water Level **340** Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature **Cool** F Quality **Clear**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Aqua Drilling & Well Service, Inc.**
Address **675 Edison Way Reno, NV 89502**

DRILLER'S LIC. NO. _____
NV. CONTRACTOR'S LIC. NO. **15291** ON SITE **2189**

Signed *Roger V. Thel*
By driller performing actual drilling on site or contractor
Dated **February 4, 2004**

7. WELL TEST DATA

TEST METHOD Bailer Pump Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		2hrs. 30mins.

Notes :

Date Started **1/26/04** Date Completed **2/4/04**