WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92205
Permit No.
Basin 105

NOTICE OF INTENT NO. 54499

1. OWNER Jose Yglesias
MAILING ADDRESS PO. Box 11965 Zephyr Cove
Zephyr Cove, NV 89448

ADDRESS AT WELL LOCATION 1770 Sunrise Pass Rd.
Minden

2. LOCATION SE 1/4 SW 1/4 Sec. 2 T 13N N/S R 20E E Douglas County
PERMIT NO. (Issued by Water Resources) 1320-02-002-059 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown coarse sand		0	100	100
Brown clay		100	105	5
Brown coarse sand some rock		105	200	95
Brown sandy clay	x	200	280	80
Coarse sand	x	280	302	22
Brown clay		302	305	3

RECEIVED 04 FEB 19 AM 11:16 STATE ENGINEERS OFFICE

Date started 2/3/2004, 19__
Date completed 2/10/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
300+		1

8. WELL CONSTRUCTION
Depth Drilled 305 Feet Depth Cased 305 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12.25 Inches		0 Feet	305 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	305

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 265 feet to 305 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 51
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 51 feet to 305 feet

9. WATER LEVEL
Static water level 181 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 2/17/04

USE ADDITIONAL SHEETS IF NECESSARY