WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 922 wF
Permit No.
Basin 105

NOTICE OF INTENT NO. 54496

1. OWNER Jerry & Mary Hayter
MAILING ADDRESS 1029 Arrowhead Dr.
Carson City, NV 89460

ADDRESS AT WELL LOCATION 1737 Sunset Ct.
Gardnerville

2. LOCATION SE 1/4 SE 1/4 Sec. 35 T 13N N/S R 20E E Douglas County
PERMIT NO. _____ Issued by Water Resources
1320-35-002-031 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand gravel & boulders		0	75	75
Sandy clay some rock		75	285	210
Fractured rock gravel	x	285	353	68

RECEIVED 04 FEB 19 AM 11:16 STATE ENGINEERS OFFICE

Date started 1/26/2004 , 19__
Date completed 2/1/2004 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100+		3

8. WELL CONSTRUCTION
Depth Drilled 353 Feet Depth Cased 353 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
9 7/8	Inches	50	Feet	353	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	353

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 313 feet to 353 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 353 feet

9. WATER LEVEL
Static water level 74 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 2/4/04

USE ADDITIONAL SHEETS IF NECESSARY