WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92274
Permit No.
Basin 105

NOTICE OF INTENT NO. 51618

1. OWNER Hank & Paula Curry
MAILING ADDRESS 1980 Pinto Cir.
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION 1980 Pinto Cir.

2. LOCATION SE 1/4 SE 1/4 Sec. 13 T 12N N/S R 20E E Douglas County
PERMIT NO. (Issued by Water Resources) | Parcel No. 1220-13-801-045 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse sand		110	152	42
Hard volcanic rock fractured	x	152	232	80
Soft zone rainbow colors	x	232	252	20
Fractured rock volcanic rainbow colors	x	252	310	58

RECEIVED 04 MAR -2 AM 10:50 STATE ENGINEERS OFFICE

Date started 2/23/2004, 19__
Date completed 2/27/2004, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
70+		3

8. WELL CONSTRUCTION
Depth Drilled 310 Feet Depth Cased 310 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6.125	Inches	110	Feet	310	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.79	.188	110	310

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 230 feet to 250 feet
From 270 feet to 310 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 2/27/04

USE ADDITIONAL SHEETS IF NECESSARY