WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92309
Permit No.
Basin: 101

NOTICE OF INTENT NO. 54532

1. OWNER Frank Woolsey
MAILING ADDRESS 2161 W. Williams Ave.
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4233 Pelican Dr. Fallon, Nv. 89406

2. LOCATION SW 1/4 NW 1/4 Sec. 21 T 19 N/S R 28 E Churchill County
PERMIT NO. (Issued by Water Resources) | Parcel No. 008-282-53 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown sand		0	11	11
brown clay		11	18	7
brown snd		18	36	18
brown clay		36	38	2
gray sand		38	61	23
brown clay		61	63	2
brown sand	xx	63	74	11

Date started 11/24/2003, 19__
Date completed 11/24/2003, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1hr

8. WELL CONSTRUCTION
Depth Drilled 74 Feet Depth Cased 74 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	74 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6pvc	3.92	.258	20	74

Perforations:
Type perforation saw cut
Size perforation 1/8
From 71 feet to 74 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 74 feet

9. WATER LEVEL
Static water level 12'6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NV. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed (By driller performing actual drilling on-site or contractor)
Date 1/5/2004

USE ADDITIONAL SHEETS IF NECESSARY