REPORT NO. A04.007

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 92472
PERMIT NO.
BASIN 85

NOTICE OF INTENT NO. 51486

1. OWNER Richard & Terry Humphrey
MAILING ADDRESS 1181 S. Taylor Fallon, NV 89406
ADDRESS OF WELL 435 Alamosa
Sparks, NV 89436

2. WELL LOCATION SE 1/4 SE 1/4 SEC. 12 T 21 R 20 E Washoe COUNTY
PERMIT NO PARCEL NO 76-290-34 SUBDIVISION NAME

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Sand & D.G.		0	6	6
D.G. & Sand		6	260	254
Granite		260	340	50
Sand, D.G. & Granite	XX	340	458	118

Notes :

Date Started 1-26-04 Date Completed 1-29-04

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		2hrs.

8. WELL CONSTRUCTION
Depth Drilled 458 Depth Cased 458

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 458 Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	458

PERFORATIONS:
Type Perforation FAC SAW Size Perforation 3/32 X 3
From 410 Feet to 450 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50'
PLACEMENT METHOD: [ ] Pumped [X] Poured
SEAL TYPE: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout [ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 458 Feet

9. WATER LEVEL
Static Water Level 338 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1981
Signed Roger Mathews
By driller performing actual drilling on site or contractor
Dated January 29, 2004