

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25558

1. OWNER Bryan Gesler ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ 5810 Mello Lane
 Las Vegas, Nev.
 2. LOCATION NW 1/4 SW 1/4 Sec. 24 T. 19S N/S R. 60 E. Clark County _____
 PERMIT NO. 125-24-301-008 Issued by Water Resources Parcel No. Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		400	430	
Caliche & Water	XX	430	450	
Caliche		450	530	
Caliche & Water	XX	530	550	
Caliche		550	600	
Caliche & Water	XX	600	635	

DONR/DWR
RECEIVED
MAR 17 2004
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 635 Feet Depth Cased 635 Feet
 HOLE DIAMETER (BIT SIZE)
 From 7.7/8 Inches To 400 Feet 635 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	PVC	SRD	+1	635

Perforations:
 Type perforation Saw Cut
 Size perforation 1/16 x 3 row
 From 575 feet to 595 feet
 From 615 feet to 635 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 120 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality _____

Date started 3/4/04, 20 _____
 Date completed 3/6/04, 20 _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 5360 N. Bonita Vista St. Contractor
Las Vegas, Nevada 89149
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed VH Dimick
 By driller performing actual drilling on site or contractor
 Date 03-09-04