

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24554

1. OWNER Wilson Family Trust ADDRESS AT WELL LOCATION 2 miles South of Panaca Jct
 MAILING ADDRESS 146 W. 200 S. Enterprise Ut 84725

2. LOCATION SE 1/4 NW 1/4 Sec. 24 T. 2 N. R. 67 E. Lincoln County
 PERMIT NO. 69447 Issued by Water Resources Parcel No. 012-100-11 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|--------------|--------------|------|-----|-----------|
| Sand, clay | | 0 | 42 | 42 |
| Sand, gravel | X | 42 | 115 | 73 |
| Clay | | 115 | 123 | 8 |
| Sand, gravel | X | 123 | 187 | 64 |
| Clay | | 187 | 200 | 13 |

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 24 Inches 0 Feet To 200 Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>16</u> | <u>52.4</u> | <u>.312</u> | <u>+3</u> | <u>200</u> |

Perforations:
 Type perforation Factory milled
 Size perforation 3/16 x 2 1/2
 From 60 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 60
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 60 feet to 200 feet

9. WATER LEVEL
 Static water level 42' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 56 °F Quality Good

Date started Sept 27, 2003
 Date completed Oct 30, 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|-----------------|------------|-------------------------------|---------------|
| <u>Air lift</u> | <u>400</u> | | <u>6 hrs</u> |
| <u>Pump</u> | <u>650</u> | <u>145'</u> | <u>30 hrs</u> |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Webber Drilling Contractor
 Address 2475 W. 3935 S. WVC, Utah 84119 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0025887
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238
 Signed Bryan Anzakne
 By driller performing actual drilling on site or contractor
 Date Nov. 15, 2003