

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25858

1. OWNER Laird and Dee Ann Whipple ADDRESS AT WELL LOCATION 2 miles South of Panaca Jet  
 MAILING ADDRESS PO Box 113 Panaca Nv. 89042  
 2. LOCATION SW 1/4 SE 1/4 Sec. 18 T. 2 N. R. 6 E Lincoln County  
 PERMIT NO. 67351 Issued by Water Resources | 012-190-08 Parcel No. | Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Perforated Well from 180' up to 52' with Mills knife - 4 cuts per foot				
Pumped 12 cu yds of neat cement through 1 1/2" Trimmie				
Plugged Linear Well Drilled for PA 67351				

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 24 Inches To 0 Feet 180 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16</u>	<u>53.4</u>	<u>.312</u>	<u>0</u>	<u>180</u>

Perforations:  
 Type perforation 3/4 x 2 Mills knife  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 180 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Webber Drilling Contractor  
 Address 2475 W. 3935 St. WVC, UT. 84119 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0025887  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238  
 Signed Bryan Arzobro By driller performing actual drilling on site or contractor  
 Date Jan. 10, 2004

Date started Dec. 9, 2003  
 Date completed Dec. 9, 2003

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)