

OFFICE USE ONLY

Log No. 92667
 Permit No. 69513/69518
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24546

1. OWNER Wynn Design & Development ADDRESS AT WELL LOCATION 3131 Las Vegas Blvd. South
 MAILING ADDRESS 3145 Las Vegas Blvd. South Las Vegas, NV.
 Las Vegas, NV.

2. LOCATION NW 1/4 NE 1/4 Sec. 16 T. 21S N/S R. 61 E. Clark County
 PERMIT NO. 69513, 69518 162-16-511-004 N/A
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Recreational Irrigation Test
 Domestic Monitor Stock
 Municipal/Industrial

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Light brown and gray-white clay w/ sand		0	115	
Pinkish brown cemented sand; some washed sand/ gravel, trace clay		115	155	
Med. brown clay, some cemented sand		155	190	
Lt. to med. cemented sand/gravel; some silt/clay		190	330	
Lt. to dark gray sand and gravel; some cemented sand		330	430	
Lt. to med. cemented sand; trace clay		430	470	
Med. brown clay; trace blue clay; some silt/sand/gravel		470	480	

8. WELL CONSTRUCTION
 Depth Drilled 480 Feet Depth Cased 480 Feet

HOLE DIAMETER (BIT SIZE)
 From 18-1/2 Inches To 480 Feet
 From 0 Feet To 480 Feet
 From 0 Feet To 480 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12-3/4		.325	+1	480
20		.325	0	65

Perforations:
 Type perforation Screen
 Size perforation .050
 From 240 feet to 440 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 65
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 0 feet to 480 feet

9. WATER LEVEL
 Static water level 93 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Thompson Drilling Co., Inc. Contractor
 Address 7227 Hauck St. Contractor
Las Vegas, NV. 89118
 Nevada contractor's license number issued by the State Contractor's Board 0004286A
 Nevada driller's license number issued by the 290 Division of Water Resources, the on-site driller.
 Signed Richard K. Thompson
 By driller performing actual drilling on site or contractor
 Date March 16, 2004

Date started February 5, 2004
 Date completed March 4, 2004

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pumped	700	150	24

