WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
**DIVISION OF WATER RESOURCES**

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 92678
Permit No.
Basin 163

NOTICE OF INTENT NO. 25224

1. OWNER PHIL Diggins
MAILING ADDRESS
ADDRESS AT WELL LOCATION BORAX AV. & YUMA ST. SANDY VALLEY NV.

2. LOCATION NW ¼ SE ¼ Sec. 16 T. 24 N R. 56 E. CLARK County
PERMIT NO. (Issued by Water Resources) 200-16-701-007 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| CLAY & GRAVEL | | 0 | 80 | 80 |
| CEMENTED ROCK & GRAVEL | | 80 | 119 | 39 |
| ROCK & GRAVEL | W.B | 119 | 140 | 21 |

UCNR/DWR
RECEIVED
MAR 1 2 2004
LAS VEGAS OFFICE

Date started 1-28, 2004
Date complated 2-23, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 5/8 | Inches | 0 Feet | 80 Feet |
| 9 7/8 | Inches | 80 Feet | 140 Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 4.33 | .316 | 0 | 140 |
| | | | | |

Perforations:
Type perforation SAW CUT
Size perforation 1/8" INCH BY 6" INCH
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 FT.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 116 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUDGET Drilling Co. (Contractor)
Address P.O. Box 3505 PAHRUMP NV. 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed (By driller performing actual drilling on site or contractor)
Date 3-11-2004

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627