WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92722
Permit No.
Basin 137 B

NOTICE OF INTENT NO. 52532

1. OWNER Round mt Gold Corp
MAILING ADDRESS P.O Box 480 Round Mountain Nevada 89045
ADDRESS AT WELL LOCATION Gold Hill

2. LOCATION SE ¼ NW ¼ Sec. 32 T. 11 N/S R. 44 E. Nye County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic Dual ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium (Sand + Gravel)		0	520	520
Clay		520	680	160
Back fill with Neat Cement from 680' to 540' 40-94# Bags Cement				
#8 Sand 38 #50 Bags		490	540	50
3/8 Hole plug 2-2500# Bags		50	490	440
Cement 17 94# Bags		0	50	50
1" Sch 40 pvc	Blank	+3	500	
1" Sch 40 pvc	Screen	500	520	
1" Sch 40 pvc	Blank	520	540	

Date started Oct 16, 2003
Date completed Oct 29, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1	N/A	96

8. WELL CONSTRUCTION
Depth Drilled 680 Feet Depth Cased Feet

HOLE DIAMETER (BIT-SIZE)

	From	To
14 3/4 Inches	0 Feet	20 Feet
8 3/4 Inches	20 Feet	680 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	sch 80	pvc	+3	500
4"	sch 80	pvc	520	540
10 3/4	3/16	wall	+3	20

Perforations:
Type perforation Horz
Size perforation .020
From 500 feet to 520 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 490 feet to 540 feet

9. WATER LEVEL
Static water level 487 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co Inc (Contractor)
Address P.O. Box 2748 (Contractor)
Elko Nevada 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1879
Signed B. R. Clf (By driller performing actual drilling on site or contractor)
Date 10-29-03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627