

Log No. 92789
 Permit No. _____
 Basin 107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48959
271 May 208
89430

1. OWNER Pete + Nancy Owen ADDRESS AT WELL LOCATION Wellington Nev. 89430
 MAILING ADDRESS P.O. Box 326 Wellington Nev. 89430
 2. LOCATION NE 1/4 NE 1/4 Sec. 11 T. 10 N/S R. 23 E. Lyon County
 PERMIT NO. 61721 | 010-631-18 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>shaly sub + clay</u>		<u>0</u>	<u>55</u>	<u>55</u>
<u>small gravel sand</u>	<input checked="" type="checkbox"/>	<u>55</u>	<u>80</u>	<u>25</u>

UTM E 0293992
 N 4291677
 NAD27

8. WELL CONSTRUCTION
 Depth Drilled 80 Feet Depth Cased 80 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 50 Feet
6 Inches 50 Feet 80 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>180</u>	<u>0</u>	<u>80</u>

Perforations:
 Type perforation 3/32 x 3 Factory
 Size perforation Factory Saw Slott
 From 50 feet to 80 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 45 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 80 °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Edmund Miller Contractor
 Address P.O. Box 97 Smith Nev. 89430 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 32166A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
 Signed Edmund Miller
 By driller performing actual drilling on site or contractor
 Date April 4 - 04

Date started April 3, 2004
 Date completed April 3, 2004

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>0</u>	<u>3 hrs</u>