WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92841
Permit No.
Basin 103

NOTICE OF INTENT NO. 50690

1. OWNER Dayton Valley Golf Club
MAILING ADDRESS 51 Palmer Drive
Dayton NV 89403

ADDRESS AT WELL LOCATION
Dayton Valley Golf Club
51 Palmer Dr Dayton NV / 13th TEE area

2. LOCATION NW ¼ NE ¼ Sec. 19 T 16 N/S R 22 E County

PERMIT NO. NEV 2001501 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clayey/sand Light Brown	-	0	7	7
Clayey/Sand redish brown		7	18	11
Clay-gray		18	20	2
Sand Fine grain Redish brown		20	25	5
Sand-Fine lite brown clay seams		25	35	10
Sand small gravels Lt brown		35	60	25
Sand-gravels 1" or less moist		60	65	5
Course sand moist		65	75	10
Course sand, small gravels wet	75'	75	90	15

Date started 4-1, 2004
Date complated 4-2, 2004

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 90 Feet Depth Cased 90 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	90 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Sch 40	0	70

Perforations:
Type perforation Factory
Size perforation .020
From 70 feet to 90 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 68
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 68 feet to 90 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Boart Longyear Co (Contractor)
Address PO Box 100 (Contractor)
Dayton NV 89403

Nevada contractor's license number issued by the State Contractor's Board 0010157

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2222

Signed [signature]
By driller performing actual drilling on site or contractor

Date 4-3-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627