


OFFICE USE ONLY  
 Log No. 92867  
 Permit No. \_\_\_\_\_  
 Basin. 104



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53390

1. OWNER LAS VEGAS PAVING ADDRESS AT WELL LOCATION WEST SIDE OF STATE HIGHWAY 15 SOUTH OF DELATOUR  
 MAILING ADDRESS 4420 S. DELATOUR LAS VEGAS NV NORTH SIDE STATE HIGHWAY 15  
ON LOMPA WEST SIDE

2. LOCATION SW 1/4 NW 1/4 Sec. 09 T. 15 S. R. 20 E County CARSON CITY NV  
 PERMIT NO. DEW-43 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE TEMP DENAT.  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other BUCKET

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ABANDON (9) WELLS ON LOMPA</u>				
<u>PULL CASING</u>				
<u>VACUUM Gravel pack from</u>				
<u>SURFACE TO 10'</u>				
<u>CEMENT GROUT Seal from 10'</u>				
<u>to surface.</u>				
RECEIVED 04 MAR 10 AM 11:38 STATE ENGINEERS OFFICE				

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)  
 From 24" To 0 Feet 40 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

\* CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8"</u>	<u>ASTM</u>	<u>F-480</u>	<u>0</u>	<u>40</u>

Perforations:  
 Type perforation Slot  
 Size perforation .092  
 From 10 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 10' G SURFACE  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  
 Concrete Grout

Gravel Packed:  Yes  No  
 From 10 feet to 40 feet

9. WATER LEVEL  
 Static water level 10' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

Date started 3-4 10:04  
 Date completed 3-4 12:04

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge  
 Name GRIFFIN DEWATERING Contractor  
 Address 560 E HAYLAND Contractor  
Ontario Cal 91761  
 Nevada contractor's license number issued by the State Contractor's Board 31246  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDG-2150  
 Signed Ed Davison  
 By driller performing actual drilling on site or contractor  
 Date 3-4-04