WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92872
Permit No.
Basin 104

NOTICE OF INTENT NO. 53390

1. OWNER Las Vegas Paving
MAILING ADDRESS 4420 S. Decatur Las Vegas NV
ADDRESS AT WELL LOCATION North of 50 Hiway on Lompa (West side) to North Ridge

2. LOCATION SW ¼ NW ¼ Sec. 09 T. 15 N/S R. 20 E. County
PERMIT NO. DEW-43 (Issued by Water Resources) — (Parcel No.) — Carson City NV (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE Temp Dewat
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
- ABANDON (8) WELLS				
- PULL CASING				
- Vacuum Gravel Pac from Surface to 10'				
- Cement GROUT Seal from 10' to Surface				

RECEIVED
04 MAR 10 AM 11:38
STATE ENGINEERS OFFICE

Date started 3-5- 1904
Date completed 3-5 1904

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)
24 Inches From 0 Feet To 40 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	ASTM	F-480	0	40

Perforations:
Type perforation Slot
Size perforation .032
From 20 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10' From Surface
Placement Method: ☐ Pumped ☐ Poured Trainer
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 10 feet to 40 feet

9. WATER LEVEL
Static water level 13 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature — °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering (Contractor)
Address 560 E Maitland Ontario Ca 91761 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS-2150
Signed Ed Davison (By driller performing actual drilling on site or contractor)
Date 3-5-04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627