WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92878
Permit No.
Basin 104

NOTICE OF INTENT NO. 53390

1. OWNER Las Vegas Paving
MAILING ADDRESS 4420 Decatur Las Vegas NV 89103
ADDRESS AT WELL LOCATION 50 Hiway and Lompa West - North Side of 50 to Humbolt

2. LOCATION SW ¼ NW ¼ Sec. 09 T. 15 N/S R. 20 E. County Carson City NV
PERMIT NO. DEW-43 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE Temp Dewat.
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Bucket.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandon 7 wells on North				
side of 50 Hiway from Lompa to				
Humbolt.				
Clean gravel pack from surface				
to 10' (s) water line -				
Seal with Concrete Grout to				
Surface from 10'				

RECEIVED 04 APR -7 AM 8:53 STATE ENGINEER'S OFFICE

Date started 4-6, 2004
Date completed 4-6, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24 Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	ASTM	F-480	0	40

Perforations:
Type perforation Slot
Size perforation .032
From 20 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10' to Surface
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 10 feet to 40 feet

9. WATER LEVEL
Static water level 6' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering Contractor
Address 534 E Maitland Contractor
Ontario Ca 91761-3317 Contractor
Nevada contractor's license number issued by the State Contractor's Board 31246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS-2150
Signed [signature] By driller performing actual drilling on site or contractor
Date 4-6-04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627