

OFFICE USE ONLY  
 Log No. 92879  
 Permit No. \_\_\_\_\_  
 Basin 104



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53390

1. OWNER LAS VEGAS PAVING ADDRESS AT WELL LOCATION 50 HIWAY AND LOMPA WEST-NORTH SIDE OF 50 TO HUMBOLT  
 MAILING ADDRESS 4420 DECATUR LAS VEGAS NV 89103

2. LOCATION SW 1/4 NW 1/4 Sec. 09 T 15 R 20 E County Carson City NV  
 PERMIT NO. DEW-43 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE TEMP DEWATS. WELL TYPE  
 Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Municipal/Industrial  Monitor  Stock  Air  Other BUCKET

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ABANDON T WELLS ON NORTH SIDE OF 50 HIWAY FROM LOMPA TO HUMBOLT.</u>				
<u>CLEAN GRAVEL PACK FROM SURFACE TO 10' @ water line -</u>				
<u>SEAL WITH Concrete Grout to Surface from 10'</u>				
STATE ENGINEERING OFFICE				

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)  
 From 24 Inches To 40 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>ASTM</u>	<u>F-480</u>	<u>0</u>	<u>40</u>

Perforations:  
 Type perforation Slot  
 Size perforation .032  
 From 20 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 10' to SURFACE  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 10 feet to 40 feet

9. 6' WATER LEVEL  
 Static water level 6' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Good

Date started 4-6-04  
 Date completed 4-6-04

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GRIFFIN DEWATERUNG Contractor  
 Address 536 E. MAHLAND Contractor  
ONTARIO Ca 91761-3317  
 Nevada contractor's license number 31246 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller AB05-2150  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 4-6-04