WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92910
Permit No.
Basin 923

NOTICE OF INTENT NO. 51624

1. OWNER Chris Peek
MAILING ADDRESS 561 Keystone Ave. Ste. 686
Reno, NV 89503

ADDRESS AT WELL LOCATION SE corner of Estates Road & Alicia Way
1865 Estates Rd

2. LOCATION SE 1/4 SE 1/4 Sec. 35 T 21N N/S R 19E E Washoe County
PERMIT NO. Issued by Water Resources
080-730-27 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG.		0	2	2
Weathered granite		2	18	16
Weathered hard granite		18	54	36
Soft weathered granite		54	60	6
Weathered granite		60	106	46
Softer fractured		106	110	4
Gray granite		110	147	37
Soft zone fractured		147	148	1
Gray hard granite		148	239	91
Fracture		239	241	2
Gray hard granite		241	259	18
Gray hard granite		259	262	3
Fracture		262	263	1
Gray hard granite		263	324	61
Fracture		324	327	3
Gray granite hard		327	362	35
Fracture		362	363	1
Gray hard granite		363	376	13
Fracture		376	377	1
Gray hard granite		377	489	112
fracture		489	490	1
Gray granite		490	496	6
Fracture	x	496	497	1
Gray hard granite		497	585	88
Soft zone fracture		585	587	2
Gray hard granite		587	591	4
Small fracture		591	592	1
Gray hard granite		592	618	26
Fracture small	x	618	619	1
Gray hard granite		619	657	38
Small fracture	x	657	658	1
Gray hard granite		658	674	16
Fracture	x	674	679	5
Continued on next page				

Date started 3/16/2004 , 19__
Date completed 3/26/2004 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		3

8. WELL CONSTRUCTION
Depth Drilled 698 Feet Depth Cased 698 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
8 3/4	Inches	50	Feet	698	Feet
	inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	698

Perforations:
Type perforation Machine cut
Size perforation 3/23 x 3
From 658 feet to 698 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 698 feet

9. WATER LEVEL
Static water level 199 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 3/29/2004

USE ADDITIONAL SHEETS IF NECESSARY

WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92910
Permit No.
Basin 092B

Page 2
NOTICE OF INTENT NO. 51624

1. OWNER Chris Peek
MAILING ADDRESS 561 Keystone Ave. Ste. 686
Reno, NV 89503

ADDRESS AT WELL LOCATION SE corner of Estates Road & Alicia Way

2. LOCATION SE 1/4 SE 1/4 Sec. 35 T 21N N/S R 19E E Washoe County
PERMIT NO. (Issued by Water Resources) 080-730-27 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granite		679	681	2
Fracture		681	682	1
Hard gray granite		682	698	16

Washoe county well permit # WL040049

RECEIVED 04 APR -5 AM 11:51 STATE ENGINEERS OFFICE

Date started 3/16/2004, 19__
Date completed 3/26/2004, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 3/29/2004

USE ADDITIONAL SHEETS IF NECESSARY