WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92916
Permit No.
Basin 101

NOTICE OF INTENT NO. 54404

1. OWNER LAHONTAN HOMES FOR D. MULLEN
MAILING ADDRESS 4700 RENO HWY
FALLON,, NV 89406

ADDRESS AT WELL LOCATION 4917 LARIAT WAY

2. LOCATION NE 1/4 SW 1/4 Sec. 16 T 18 N/S R 28 E CHURCHILL County
PERMIT NO. (Issued by Water Resources) 006-171-41 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	
BROWN SAND		1	17	16
BROWN CLAY		17	20	3
BROWN SAND		20	30	10
GRAY SAND		30	65	35
GRAY CLAY		65	70	5
BROWN SAND		70	81	11
BROWN CLAY		81	83	2
GRAY SAND		83	100	17
GRAY CLAY		100	110	10
GRAY SANDS/CLAYS		110	145	35
GRAY CLAY		145	147	2
BROWN SANDS	X	147	160	13

04 MAR 25 AM 10:54
STATE ENGINEER'S OFFICE

Date started 3/12/2004, 19__
Date completed 3/12/2004, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 HR

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	100	Feet
6	Inches	100	Feet	160	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	160

Perforations:
Type perforation MACHINE PERF
Size perforation .080
From 153 feet to 158 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 11'1" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed (By driller performing actual drilling on-site or contractor)
Date 3/22/2004

USE ADDITIONAL SHEETS IF NECESSARY