


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 92952
 Permit No. _____
 Basin 61



NOTICE OF INTENT NO. 52587

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Barrick Goldstrike Mines PZ00-3 ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV.
 MAILING ADDRESS P.O. Box 29
Elko, NV 89803

2. LOCATION SW 1/4 NE 1/4 Sec. 19 T 36N N/S R 50 E Eureka County
 PERMIT NO. N/A Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned by pumping both tubes full of neat cement.				
Had to use some hole plug to stop cement from continually leaking out of tubes.				
Quantities Used:				
1: Cement = 53.5 cu.ft.				
Hole plug = 2.8 cu.ft.				
2: Cement = 53.5 cu.ft.				
Hole plug: 1.4 cu.ft.				
Original Construction:				
Cement		0	51	51
Hole plug		51	273	222
Gravel pack		273	305	32
Hole plug		305	334	29
Gravel pack		334	345	11
Transducer			340	
Hole plug		345	375	30
Gravel pack		375	426	51
Hole plug		426	450	24

8. WELL CONSTRUCTION
 Depth Drilled 450 Feet Depth Cased 420 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>14.75</u>	<u>0</u>	<u>24</u>	<u>24</u>
<u>7.875</u>	<u>24</u>	<u>450</u>	<u>426</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10.75</u>	<u>28.04</u>	<u>0.250</u>	<u>+2</u>	<u>24</u>
<u>1: 2.375</u>	<u>5.02</u>	<u>0.218</u>	<u>+2</u>	<u>420</u>
<u>2: 2.375</u>	<u>5.02</u>	<u>0.218</u>	<u>+2</u>	<u>300</u>

Perforations:
 Type perforation Slot
 Size perforation 0.125"

From	To	Feet
<u>1: 380</u>	<u>420</u>	<u>40</u>
<u>2: 280</u>	<u>300</u>	<u>20</u>

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 51' Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From See Detail feet to _____ feet

9. WATER LEVEL
 Static water level 1: 334', 2: 280' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2210
 Signed Fred Ussie
 By driller performing actual drilling on-site or contractor
 Date 2/26/04

Date started 2/20/2004, 19
 Date completed 2/20/2004, 19

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Draw Down (Feet Below Static)			
Time (Hours)			

1351