CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92967
Permit No.
Basin 101

NOTICE OF INTENT NO. 54392

1. OWNER MIKE CASEY
MAILING ADDRESS 1550 ALLEN ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 1130 HEIDI

2. LOCATION NW 1/4 SE 1/4 Sec. 20 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources
~~007-122-02~~ Parcel No. 08-176-59
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	
BROWN SAND		1	15	14
BROWN CLAY		15	18	3
BROWN SAND		18	45	27
GRAY SAND		45	90	45
BROWN CLAY		90	92	2
BROWN SAND	X	92	107	15

RECEIVED
04 FEB 18 AM 10:58
STATE ENGINEERS OFFICE

Date started 1/19/~~1904~~ 20, 19__
Date completed 1/19/~~1904~~ 20, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 HR

8. WELL CONSTRUCTION
Depth Drilled 107 Feet Depth Cased 107 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 1/4	Inches	50	Feet	107	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	107

Perforations:
Type perforation MACHINE LOT
Size perforation .080
From 100 feet to 105 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Gravel Packed: [ ] Yes [X] No
From feet to feet

Seal Type:
[ ] Neat Cement
[X] Cement Grout
[ ] Concrete Grout

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed [signature] By driller performing actual drilling on-site or contractor
Date 2/14/200

USE ADDITIONAL SHEETS IF NECESSARY