



Log No. 42969  
 Permit No. \_\_\_\_\_  
 Basin 106

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48952

1. OWNER Jam Properties ADDRESS AT WELL LOCATION 485 Hwy 208 Wellington Nev. 89444  
 MAILING ADDRESS PO Box 169 Smith Nev. 89430  
 2. LOCATION NE 1/4 NE 1/4 Sec. 14 T. 10 N/S R. 22 E. Douglas County  
 PERMIT NO. 11022-14-001024 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>almond top soil + small rocks</u>	<u>No</u>	<u>0</u>	<u>20</u>	<u>20</u>
<u>Yellow clay + small rocks</u>	<u>No</u>	<u>20</u>	<u>47</u>	<u>27</u>
<u>gravel</u>	<u>No</u>	<u>47</u>	<u>76</u>	<u>29</u>
<u>gravel + coarse pipes</u>		<u>76</u>	<u>109</u>	<u>33</u>
<u>yellow clay + coarse sand</u>		<u>109</u>	<u>156</u>	<u>47</u>
<u>Coarse sand some gravel</u>		<u>156</u>	<u>200</u>	<u>44</u>

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches 90 Feet To 60 Feet  
6 Inches 60 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>1 8/8</u>	<u>0</u>	<u>200</u>

Perforations:  
 Type perforation factory saw slits  
 Size perforation 3/32 x 3  
 From 160 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level: 100 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Edmund Miller Drilling Contractor  
 Address PO. Box 92 Smith Nev 89430  
 Nevada contractor's license number issued by the State Contractor's Board: 32166 A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 719  
 Signed Edmund Miller  
 By driller performing actual drilling on site or contractor  
 Date Jan 31-04

Date started Jan 20 04  
 Date completed Jan 30 04

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>pumped</u>	<u>20</u>	<u>5 ft</u>	<u>3 hrs</u>