WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. ~~18153~~ 92983
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER RAND CONSTRUCTION ADDRESS 1320 BRENDAWAY East Washoe

2. LOCATION NW ¼ NW ¼ Sec. 30 T. 17N N/S R. ~~[illegible]~~ E. 20E Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN SAND		0	6	6
SAND & D.G.		6	80	74
COURSE D.G.		80	155	75
SMALL GRAVEL & DG.	160	155	175	20
D.G. - GRAVEL WITH CLAY		175	180	5
T.D. = 180				

Date started NOV. 28, 1978
Date completed NOV. 29, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
BLEW WELL FOR 1½ HRS. 650 C.F.M. - 250 P.S.I.			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. 10 5/8 TO 50' WELL CONSTRUCTION
Diameter hole 8 3/4 inches Total depth 180 feet
Casing record 6 5/8
Weight per foot 12.9 Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	180 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CONCRETE
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 180 feet

Perforations:
Type perforation FACTORY
Size perforation 1/16 - 3
From 150 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 100 Feet below land surface 80
Flow 12 G.P.M.
Water temperature COOL ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AQUA DRILLING & WELL SERVICES
Address P.O. BOX 2143
Nevada contractor's license number 15921
Nevada driller's license number 1062
Signed Edward A. Harrison
Date NOV. 29, 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471