WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92987
Permit No.
Basin 90

NOTICE OF INTENT NO. 54492

1. OWNER Mark & Kathy Dornstauder
MAILING ADDRESS 8805 Little Creek Rd.
Reno, NV 89506

ADDRESS AT WELL LOCATION 1210 Bedell Rd

2. LOCATION NE 1/4 NW 1/4 Sec. 7 T 22N N/S R 19E E Washoe County
PERMIT NO. Issued by Water Resources
079-382-50 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	59	58
Dark brown sandy clay		59	63	4
Brown sandy clay		63	70	7
Granite sandy	x	70	73	3
Brown sandy clay		73	110	37
Coarse sand soft	x	110	124	14
sandy clay gray		124	130	6
Soft zone	x	130	141	11
Gray sandy clay		141	159	18
Soft zone	x	159	189	30
Gray sandy clay		189	200	11

Washoe county well permit # WL 030279

RECEIVED 04 FEB 27 AM 11:35 STATE ENGINEER'S OFFICE

Date started 2/20/2004, 19__
Date completed 2/25/2004, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
38		3

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
8 1/2	Inches	50	Feet	200	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	200

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 113 feet to 133 feet
From 173 feet to 193 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on site or contractor
Date 2/25/04

USE ADDITIONAL SHEETS IF NECESSARY