

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24806

Well # MCF-08
 1. OWNER Basic Remediation Co. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 875 Warm Springs Rd Warm Springs Rd & Pabco Rd
Henderson, NV 89015 Henderson, NV
 2. LOCATION NW 1/4 NE 1/4 Sec. 36 T. 21 N. 62 E. County _____
 PERMIT NO. 161-36-101-002 Parcel No. _____ Subdivision Name BMI Site
 Issued by Water Resources _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SILTY SAND w/ GRAVEL*		0	43	43
SILTY GRAVEL w/ SAND		43	54	11
SILTY SAND		54	68	14
SILT		68	133	65
SILTY CLAY w/ SAND		133	137	4
CLAYEY SILT		137	198	61
SILTY CLAY		198	203	5
CLAYEY SILT		203	208	5
SILTY CLAY/CLAYEY SILT		208	233	25
CLAYEY SILT		233	258	25
SILTY CLAY		258	263	5
SILT		263	400	137

* = some local cobbles

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 370 Feet
 HOLE DIAMETER (BIT SIZE)
9 7/8 Inches From 0 Feet To 400 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2</u>		<u>Sch 80 PVC</u>	<u>0</u>	<u>350</u>
<u>4 1/2</u>		<u>Perf. Sch 80 PVC</u>	<u>350</u>	<u>370</u>

Perforations:
 Type perforation Factory Slotted
 Size perforation 0.010-inch slot width
 From 350 feet to 370 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 336 feet
 Placement Method: Pumped Poured
 Gravel Packed: Yes No (10x20 silica sand)
 From 343.5 feet to 374.5 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started March 9, 2004
 Date completed March 20, 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WOC Exploration & Wells
 Address 1421 S. 39th Avenue
Phoenix, AZ 85009
 Nevada contractor's license number issued by the State Contractor's Board 0012852
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1747
 Signed _____
 By driller performing actual drilling on site or contractor
 Date 3/22/04