WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

USE ADDITIONAL SHEETS IF NECESSARY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93136
Permit No. 57700
Basin 162

NOTICE OF INTENT NO. 26366

1. OWNER FRED CRESSLER
MAILING ADDRESS 3031 TILLMAN
PAHRUMP, NV

ADDRESS AT WELL LOCATION 3031 TILLMAN

2. LOCATION SW 1/4 SW 1/4 Sec. 31 T 21 N/S R 54 E NYE County
PERMIT NO. 57700 Issued by Water Resources
45-441-16 Parcel No.
CAL-VISTA SUBDIVISION Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
EXISTING WELL		0	350	350
GRAVEL	WB	350	460	110

DCNR/DWR
RECEIVED
MAY 14 2004
LAS VEGAS OFFICE

Date started 4/28/2004 , 19__
Date completed 4/29/04 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXISTING	Inches	0	Feet	350	Feet
9.5	Inches	350	Feet	460	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
EXISTING			0	350
6.625	12.92	.188	340	460

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3

From	340	feet to	360	feet
From	380	feet to	400	feet
From	420	feet to	440	feet
From		feet to		feet
From		feet to		feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal EXISTING
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on-site or contractor
Date 5/7/2004