WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93150
Permit No.
Basin 101

NOTICE OF INTENT NO. 54394

1. OWNER FERGUSON CONSTRUCTION
MAILING ADDRESS WILLIAMS AVENUE
FALLON, NV 89406

ADDRESS AT WELL LOCATION 1028 MCLEAN

2. LOCATION ~~NE~~ NW 1/4 NE 1/4 Sec. 33 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. RL 3-2-04 Issued by Water Resources
008-693-04 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	
BROWN SAND		1	18	17
BROWN CLAY		18	21	3
BROWN SAND		21	40	19
GRAY SAND		40	78	38
BROWN CLAY		78	79	1
BROWN SAND		79	95	16
BROWN CLAY		95	98	3
BROWN SILT/CLAY		98	120	22
GRAY SAND/CLAY		120	160	40
BROWN CLAY		160	165	5
BROWN SANDS/GRAVELS	X	165	179	14

RECEIVED 04 FEB 18 AM 10:59 STATE ENGINEERS OFFICE

Date started 1/20/~~1904~~ 20, 19__
Date completed 1/20/~~1904~~ 20, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		1 HR
45	42'2"	1 HR

8. WELL CONSTRUCTION
Depth Drilled 179 Feet Depth Cased 179 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 1/8	Inches	50	Feet	179	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	179

Perforations:
Type perforation MACHINE SLIT
Size perforation .080
From 172 feet to 179 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 26'4" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed
By driller performing actual drilling on-site or contractor
Date 2/9/2004

USE ADDITIONAL SHEETS IF NECESSARY